



NOTE:

1. WIDTH OF PERIMETER TREATMENT (A OR B) SHALL BE 10% OF THE BUILDING'S NARROWEST WIDTH (W) OR 40% OF THE BUILDING EAVE HEIGHT (H), WHICHEVER IS LESS, WITH 4' (1.22 m) BEING THE MIN. FOR STANDARD GAF GUARANTEE REQUIREMENTS. SEE HALF-SHEET REQUIREMENTS IN MECHANICALLY ATTACHED SECTION.
2. FOR ADHERED, SELF-ADHERED, AND RHINO BOND SYSTEMS, SEE INSULATION TABLE FOR ENHANCEMENTS.



www.gaf.com
1 Campus Drive,
Parsippany, NJ 07054

EverGuard
SINGLE-PLY ROOFING SYSTEMS
FIELD OF ROOF
SERIES

DRAWING #

106

SCALE
N.T.S.

ROOF AREA ZONE LAYOUT DETAIL

THIS DETAIL APPLIES TO:
Adhered Systems
Ballasted Systems
Mechanically Attached Systems
Self - Adhered Systems
Rhino Bond Systems

REVISION DATE
6-1-16