



NOTE:

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICAL SYSTEMS ONLY.
2. FIELD-FABRICATED EXPANSION JOINT SHOULD BE SMOOTH BACKED MEMBRANE ONLY
3. APPLY EVERGUARD® TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES (REFER TO EVERGUARD® DETAIL 115).



EverGuard
SINGLE-PLY ROOFING SYSTEMS
EXPANSION JOINT
SERIES

DRAWING #
404B

SCALE
N.T.S.

**FIELD FABRICATED WALL
EXPANSION JOINT DETAIL - CURB
TYPE**

THIS DETAIL APPLIES TO:

ALL SYSTEMS

REVISION DATE
5-25-16

www.gaf.com
1 Campus Drive,
 Parsippany, NJ 07054