



PREFERRED 2-PLY ALTERNATE

NOTE:

1. SHEET LEAD MINIMUM OF 2-1/2 POUNDS PER SQUARE FOOT (12.2 KG PER SQUARE METER).
2. MINIMUM 18" (457 mm) CLEARANCE FROM PIPES, WALLS, AND CURBS.
3. FOR HEAT-WELD OR TORCH-APPLIED RUBEROID®MB, TORCH THE AREA OF RUBEROID®MB OVER WHICH THE METAL IS TO BE PLACED TO A MOLTEN STATE. PRESS THE PRIMED FLANGE INTO THE MODIFIED BITUMEN WHILE IT IS STILL MOLTEN.



GAFGLAS®
Built-Up Roofing Systems
RUBEROID®
Modified Bitumen Roofing Systems

VENT STACK FLASHING DETAIL

DRAWING #

15

SYSTEM

MB/BUR

SCALE

N.T.S.

ISSUE/ REVISION DATE

7-01-14