



**NOTE:**

1. THIS DETAIL ALLOWS WALL AND DECK TO MOVE INDEPENDENTLY.
2. THIS DETAIL SHOULD BE USED WHERE THERE IS ANY POSSIBILITY THAT DIFFERENTIAL MOVEMENT WILL OCCUR BETWEEN THE DECK AND A VERTICAL SURFACE, SUCH AS AT A PENTHOUSE WALL. THE VERTICAL WOOD MEMBER SHOULD BE FASTENED TO THE DECK ONLY. THIS IS ONE SATISFACTORY METHOD OF JOINING THE TWO PIECE FLASHING SYSTEM. OTHER METHODS MAY BE USED.
3. COUNTER FLASHING MUST EXTEND AT LEAST 4" BELOW THE TOP EDGE OF THE BASE FLASHING AND 3" BELOW BASE FLASHING FASTENERS.



**GAFGLAS®**  
Built-Up Roofing Systems  
**RUBEROID®**  
Modified Bitumen Roofing Systems

**BASE FLASHING DETAIL FOR  
NON-WALL SUPPORTED DECK**

DRAWING #

**04**

SYSTEM

**MB/BUR**

SCALE

N.T.S.

ISSUE/ REVISION DATE

10-01-10