



**NOTE:**

1. MASONRY WALLS TO BE PRIMED PRIOR TO FLASHING. WOOD WALLS REQUIRE BASE SHEET NAILED TO WALL 8" O.C. ALONG TOP AND LAPS AND 8" O.C. THROUGHOUT THE FIELD OF THE BASE SHEET ON THE WALL.
2. WALL COVERINGS TURNED OVER EDGE A MINIMUM OF 1 1/2" (38mm) OR THICKNESS OF NAILER WHICHEVER IS GREATER.
3. REFER TO DETAIL MB / BUR 7 FOR ALTERNATE WALL FLASHING METHOD.
4. FASTEN BASE FLASHING APPROXIMATELY 8" O.C. FOR HEIGHTS UP TO 12" AND 4" O.C. FOR HEIGHTS UP TO 24".
5. FOR WALL FLASHINGS IN EXCESS OF 4' CONTACT GAF TECHNICAL SERVICES AT 1-800-ROOF-411.



**GAFGLAS**  
Built-Up Roofing Systems  
**RUBEROID**  
Modified Bitumen Roofing Systems

## ALTERNATE HIGH PARAPET WALL DETAIL

DRAWING #

**07**

SYSTEM

**MB/BUR**

SCALE

N.T.S.

ISSUE/ REVISION DATE

10-01-10