



NOTE:

1. MINIMUM SLOPE IS 2:12.
2. THE FOLLOWING APPLIES FOR MA SYSTEMS ONLY: FOR INSULATION THICKNESSES GREATER THAN 8", CONTACT GAF CONTRACTOR SERVICES FOR ALTERNATE ATTACHMENT REQUIREMENTS. THESE METHODS MAY INCLUDE THE USE OF A HARD BOARD COVERING THE ASSEMBLY.
3. APPLY EVERGUARD® TPO AND PVC CUT EDGE SEALANT TO ALL CUT REINFORCED TPO AND PVC EDGES (REFER TO DETAIL MA/FA/BA 115).



SPECIAL
CONSTRUCTION
SERIES

TERMINATION AT SLOPED ROOF

DRAWING #

601

SCALE

N.T.S.

SYSTEM

MA/FA/BA

ISSUE/ REVISION DATE

3-1-10