

Master Flow[®] SSB960 Static Roof Louver

Miami-Dade County Notice of Acceptance (NOA)

Updated: 1/08



*Quality You Can Trust...From
North America's Largest Roofing Manufacturer!™*

www.gaf.com



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

LL Building Products, Inc.
295 McKoy Road
Burgaw, NC 28425

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SSB 960 Static Roof Louver

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA No. 07-0418.03 and consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.

NOA No.: 07-1030.06
Expiration Date: 01/31/13
Approval Date: 01/31/08
Page 1 of 4



ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Ventilation
Materials: Aluminim

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SSB960 Roof Louvers	Vent Ht.: 4.93" Vent Width: 11.52" Vent Length: 15 1/4" Base: 18"x 20 1/2" Min. Embossed Thickness: 0.025"	TAS 100(A)	Aluminum static louvered roof ventilation system

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Asphalt Roof Cement		ASTM D 4586	Asbesto-free, asphalt based roof cement.	Generic
Asphalt Primer		ASTM D 41	Asphalt Primer	Generic
Roofing Nails	Minimum #12 x 1 1/4"	TAS 114	Corrosion resistant annular ring shank nails	Generic

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
PRI Construction Materials	LLB-016-02-01	TAS 100(A)	September 2007
Celotex Corporation Testing Services	520368	TAS 100(A)	August 1999

NOA No.: 07-1030.06
 Expiration Date: 01/31/13
 Approval Date: 01/31/08
 Page 2 of 4



APPROVED APPLICATIONS

Tradename: SSB960

System Type C: Mechanical attachment of static vent over composite shingles.

Cutout: Vents shall be evenly centered. Center the vent hole between rafters and 18" max. down from the ridge line to keep the top of the roof vent below the ridge line. Mark this position.

Using marked position as center point, scribe a circle that is the same diameter as the vent throat opening. Starting with the drill hole cut vent hole.

Installation: Vents should be evenly spaced on the rear slope of the roof.

Remove roofing nails from top row of shingles so the flashing of the roof vent will slide under shingles. Apply approved roof cement around the edge of the hole. Carefully slide base of vent under shingles with non-louvered, slant back facing the peak of roof. Make sure the throat of the vent is centered over vent hole. Fasten the base to roof decking at all corners and 4" o.c. 1" from edge of the vent flange with 1-3/4" x 3/8" annular ring shank nails. (See SSB960 louver roof vent profile drawing). Seal all seams and nail heads with roofing cement.

Net Free Area:

See Manufacturer's Specifications

**Minimum
Slope:**

2:12


GENERAL LIMITATIONS:

1. LL Building Products, Inc. SSB960 Roof Louvers shall not be installed on roof mean heights greater than 33 feet.




NOA No.: 07-1030.06
Expiration Date: 01/31/13
Approval Date: 01/31/08
Page 3 of 4

**SSB960 STATIC VENT
DETAIL
FRONT VIEW**



SIDE VIEW



END OF THIS ACCEPTANCE

