

Nemo letc.

Certificate of Authorization #32455 353 Christian Street, Unit #13 Oxford, CT 06478 (203) 262-9245

ENGINEER TEST CONSULT

P.E. EVALUATION REPORT (PEER)

GAF

1 Campus Drive Parsippany, NJ 07054 (800) 766-3411 PEER-GAF-004.B.R14 FL17649-R14

Date of Issuance: 12/16/2015 Revision 14: 01/30/2025

SCOPE:

This P.E. Evaluation Report (henceforth 'PEER') is issued under **F.A.C. Rule** <u>61G20-3</u> and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for use of the product under the Florida Building Code. The product described herein has been evaluated for compliance with the **8**th **Edition** (2023) **Florida Building Code** <u>sections noted herein</u>.

DESCRIPTION: GAF Silicone Roof Coatings

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.


CONTINUED COMPLIANCE: This PEER is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our PEERs by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance, or the production facility location(s). NEMO ETC, LLC requires a complete review of its PEER relative to updated Code requirements with each Code Cycle.

ADVERTISEMENT: "NEMO P.E. Evaluated" may be displayed in advertising literature. If any portion of the PEER is displayed, then it shall be in its entirety.

INSPECTION: Upon request, a copy of this entire PEER shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This PEER consists of pages 1 through 4.

Prepared by:



CERTIFICATION OF INDEPENDENCE:

- 1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
- 2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
- 3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the PEERs are being issued.
- 4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
- 5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

©2018, NEMO ETC, LLC



ROOFING COMPONENT EVALUATION:

1. SCOPE:

Product Category: Roofing

Sub-Category: Cements – Adhesives – Coatings

Product Approval Method: Method 1, Option D – Codified Material, Evaluation by Engineer

Compliance Statement: GAF Silicone Roof Coatings, as outlined herein and produced by GAF, have demonstrated compliance with the 8th Edition (2023) Florida Building Code, including High Velocity Hurricane Zones (HVHZ), through testing in accordance with the Standards set forth herein. Compliance is subject to the <u>Limitations of Use</u> and <u>Installation Requirements</u> set forth herein.

2. STANDARDS:

SECTION	PROPERTY	<u>Standard</u>
1507.14.3, 1509.2, R905.14.3,	Material standard	ASTM D6694
R905.15.2, TAS 110		

3.	REFEREN	

EXAMINATION	REFERENCE	<u>Date</u>
ASTM D6694	4p-GAF-21-SSLAP-01.A	07/13/22
ASTM D6694	RMLC-049-02-01	05/06/15
ASTM D6694, adhesion	743T0001	09/10/19
ASTM D6694	376T0425.1	04/02/24
ASTM D6694, adhesion	376T0425.2	04/02/24
ASTM D6694, adhesion	376T0598	01/16/25
Traceability	FBC CLA	09/01/21
Quality Assurance	Service Confirmation (IL)	07/12/22
Quality Assurance	Service Confirmation (OH)	11/21/24
	ASTM D6694 ASTM D6694, adhesion ASTM D6694, adhesion ASTM D6694, adhesion ASTM D6694, adhesion Traceability Quality Assurance	ASTM D6694

4. PRODUCT DESCRIPTION:

1 ROBOCI DESCRII HORI						
TABLE 1: EVALUATED COATINGS						
Product	Material Standard	Use	PLANT(S)			
GAF Unisil Silicone Roof Coating	ASTM D6694	Restorative Membrane	Alc:n II			
GAF Unisil High Solids Silicone Roof Coating	ASTM D6694	Restorative Membrane	Alsip, IL			
GAF High Solids Silicone Roof Coating	ASTM D6694	Restorative Membrane	Avon Lake, OH			

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose. PEERs are not to be construed as representing any attributes not specifically listed, nor are PEERs to be construed as an endorsement of the subject, or a recommendation for its use. There is no warranty by NEMO ETC, LLC or Robert Nieminen, P.E., express or implied, as to any finding or other matter in this PEER, or as to any product covered by the PEER.
- 5.2 This PEER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- 5.3 This PEER does not include evaluation of fire classification. Refer to **FBC 1505 or FBC HVHZ 1516** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.



- 5.4 **GAF Silicone Roof Coatings** are components for use in Approved roof assemblies. Refer to the "Approved Use" in Section 4 for each component. The coatings noted herein are not purported to be Roofing Systems, and their use shall be governed by and limited to applications where Roof System Product Approval is not necessary (e.g., maintenance and repair) or where the components are called out in a Roof System Product Approval.
- 5.5 The existing roof system and/or substrate shall meet wind uplift requirements of the project to the satisfaction of the Authority Having Jurisdiction.
- 5.6 All products listed herein shall have quality assurance audit in accordance with **F.A.C. Rule** 61G20-3 requirements.

6. Installation:

- 6.1 **GAF Silicone Roof Coatings** shall be installed in accordance with **GAF** published installation instructions, subject to the Approved Use in Section 4 and Limitations of Use herein.
- 6.1.1 Foundation coat(s), reinforcing fabric (when installed) and/or finish coat(s) shall be in accordance with GAF wetmil and dry-mil thickness requirements.
- 6.2 Allowable Substrates:

TABLE 2: ALLOWABLE SUBSTRATES					
GAF Unisil Silicone Roof Coating and GAF Unisil High Solids Silicone Roof Coating					
Substrate					
Туре	SURFACE	CONDITION	Primer	FOUNDATION AND/OR FINISH COAT(s)	
Modified Bitumen, APP	Granule	New or Existing (aged)	(Optional) GAF PVC Primer for Silicone	GAF Unisil High Solids Silicone Roof Coating	
Modified Bitumen, SBS	Granule	New or Existing (aged)	(Optional) GAF PVC Primer for Silicone		
Single Ply, EPDM	N/A	New or Existing (aged)	None		
Single Ply, TPO	N/A	New or Existing (aged)	GAF TPO Primer for Silicone		
Spray Applied Polyurethane Foam	N/A	New	None	GAF Unisil Silicone Roof Coating or GAF Unisil High Solids Silicone Roof Coating	
Structural Concrete	N/A	New or Existing (aged)	None	GAF Unisil Silicone Roof Coating or GAF Unisil High Solids Silicone Roof Coating	

TABLE 3: ALLOWABLE SUBSTRATES				
GAF HIGH SOLIDS SILICONE ROOF COATING				
Substrate			FOUNDATION AND/OR	
Түре	SURFACE	CONDITION	Primer	FINISH COAT(s)
Built-up roof (BUR)	Granule	New or Existing (aged)	GAF Asphalt Bleed-Block Primer or GAF Multi-Purpose Primer	
Galvanized Metal	N/A	New or Existing (aged)	None	
Modified Bitumen, APP	Granule	New or Existing (aged)	GAF Asphalt Bleed-Block Primer or GAF Multi-Purpose Primer	
Modified Bitumen, APP	Smooth	New or Existing (aged)	GAF Asphalt Bleed-Block Primer or GAF Multi-Purpose Primer	GAF High Solids Silicone Roof Coating
Modified Bitumen, SBS	Granule	New or Existing (aged)	GAF Asphalt Bleed-Block Primer or GAF Multi-Purpose Primer	Rooi Coating
Modified Bitumen, SBS	Smooth	New or Existing (aged)	GAF Asphalt Bleed-Block Primer or GAF Multi-Purpose Primer	
Single Ply, TPO	N/A	Existing (aged)	GAF Multi-Purpose Primer	
Spray Applied Polyurethane Foam	N/A	New	None	



7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the named QA entity for manufacturing facilities covered by **F.A.C. Rule** <u>61G20-3</u> QA requirements. Refer to <u>Section 4</u> herein for products and production locations having met codified material standards.

9. QUALITY ASSURANCE ENTITY:

<u>UL, LLC – QUA9625</u>: (360) 817-5512; <u>bsai.inspections@ul.com</u>

- END OF PEER -

