



**MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 315-2599

**DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION**

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**NOTICE OF ACCEPTANCE (NOA)**

**GAF  
1 Campus Drive  
Parsippany, NJ 07054**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: EverGuard® PVC XK Fleeceback Single Ply Roof Systems over Lightweight Insulating Concrete Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 13-0603.11 and consists of pages 1 through 7.  
The submitted documentation was reviewed by Hamley Pacheco, P.E.



**NOA No.: 18-0213.10  
Expiration Date: 03/14/23  
Approval Date: 03/22/18  
Page 1 of 7**

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Single Ply Roofing  
**Material:** PVC  
**Deck Type:** Lightweight Concrete  
**Maximum Design Pressure:** -420 psf

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**  
**TABLE 1**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard® PVC XK Fleeceback	60 mil thick 10' x 90' 76" x 90' 80 mil thick 10' x 75' 76" x 75'	ASTM D4434	Polyester felt-backed PVC membrane for application in hot asphalt or adhesive.
LRF Adhesive M	Dual component cylinders	proprietary	A two component, one-step, all purpose foamable adhesive.
LRF Adhesive O	Dual component cylinders	proprietary	A two component, one-step membrane foamable adhesive.
EverGuard® PVC Round Stack	Various	proprietary	PVC membrane molded to wrap around round roof structures.
EverGuard® PVC Outside Corner	6x6	proprietary	Outside corner of base and curb flashing.
EverGuard® PVC Corner Curb Flashing	Various	proprietary	Corners are fabricated from reinforced PVC membrane.
EverGuard® PVC Square Tube Wrap	Various	proprietary	PVC membrane molded to wrap around square roof structures.
EverGuard® PVC Inside Corner	6 x 6 x 5-1/4	proprietary	Inside corner of base and curb flashing.
EverGuard® PVC Coated Metal	Various	proprietary	Un-reinforced membrane is laminated to galvanized sheet metal.
Topcoat® Elastomeric Roofing Membrane	1, 5 or 55gal.	ASTM D6083	An acrylic, water based elastomeric membrane system used to protect various types of roofing surfaces



**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
N/A	N/A	N/A

**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	N/A	N/A	N/A	N/A

**EVIDENCE SUBMITTED:**

<b><u>Test Agency/Identifier</u></b>	<b><u>Report</u></b>	<b><u>Test Name</u></b>	<b><u>Date</u></b>
Trinity-ERD	ERD F42130.06.13-1	ASTM D4434-06	06/05/13
Atlantic & Caribbean Roof Consulting, LLC	11-066	TAS 114-D	11/21/11
	12-027	TAS 114-D	10/22/12
	12-028	TAS 114-D	05/22/12
PRI Construction Materials Technologies, LLC	GAF-499-02-01	ASTM D6083	03/11/14



**APPROVED ASSEMBLIES:**

- Membrane Type:** Single Ply, PVC
- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Elastizel Lightweight Insulating Concrete, over minimum 3,000 psi structural concrete deck.
- System Type F(1):** Membrane is fully adhered to Lightweight Insulating Concrete roof deck.
- Deck:** Minimum of 2” thickness of Elastizel Lightweight Insulating Concrete with a minimum compressive strength of 300 psi.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

- Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the substrate with LRF Adhesive O, applied in ¾” wide ribbons spaced 6” o.c. The laps are heat welded a minimum of 1-1/2 width for automatic machine welding. Weld width shall be minimum 2” width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.
- Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer’s instructions.
- Maximum Design Pressure:** -112.5 psf, (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC

**Deck Type 4:** Lightweight Concrete, Non-Insulated

**Deck Description:** Mearlcrete Lightweight Insulating Concrete, over minimum 3,000 psi structural concrete deck.

**System Type F(2):** Membrane is fully adhered to Lightweight Insulating Concrete roof deck.

**Deck:** Minimum of 2" thickness of Mearlcrete Lightweight Insulating Concrete with a minimum compressive strength of 750 psi.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the substrate with LRF Adhesive M, applied in 1" wide ribbons spaced 6" o.c. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -162.5 psf, (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 4I:** Lightweight Concrete, Non-Insulated  
**Deck Description:** Mearlcrete Lightweight Insulating Concrete, over minimum 3,000 psi structural concrete deck.  
**System Type F(3):** Membrane is fully adhered to Lightweight Insulating Concrete roof deck.  
**Deck:** Minimum of 2” thickness of Mearlcrete Lightweight Insulating Concrete with a minimum compressive strength of 750 psi.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the substrate with LRF Adhesive O applied in 1” wide ribbons spaced 6” o.c. The laps are heat welded a minimum of 1-1/2 width for automatic machine welding. Weld width shall be minimum 2” width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer’s instructions.

**Maximum Design Pressure:** -420 psf, (See General Limitation #9.)



## LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gauge attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 18-0213.10  
Expiration Date: 03/14/23  
Approval Date: 03/22/18  
Page 7 of 7