



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599
www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Conventional Built-Up-Roof Systems over Poured Gypsum Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-0424.12 consists of pages 1 through 9.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 13-1022.17
Expiration Date: 12/11/18
Approval Date: 02/26/15
Page 1 of 9

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	BUR
Material:	Fiberglass
Deck Type:	Poured Gypsum
Maximum Design Pressure:	-75 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
GAFGLAS® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D4601	Type II asphalt impregnated and coated glass mat base sheet.
GAFGLAS® #80 Ultima™ Base Sheet	39.37" (1 meter) Wide	ASTM D4601	Type II asphalt impregnated and coated, fiberglass base sheet.
GAFGLAS® FlexPly™ 6	39.37" (1 meter) Wide	ASTM D2178	Type VI asphalt impregnated glass felt with asphalt coating.
GAFGLAS® Ply 4	39.37" (1 meter) Wide	ASTM D2178	Type IV asphalt impregnated glass felt with asphalt coating.
GAFGLAS® Stratavent® Perforated Venting Base Sheet	39.37" (1 meter) wide	ASTM D4897	Fiberglass base sheet impregnated and coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating with factory perforations.
GAFGLAS® Stratavent® Nailable Venting Base Sheet	39.37" (1 meter) wide	ASTM D4897	Fiberglass base sheet impregnated and coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating.
Ruberoid® HW 25 Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced torch applied SBS base sheet reinforced with a fiberglass mat.
Ruberoid® HW Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced torch applied SBS base sheet reinforced with a polyester mat.
Ruberoid® 20 Smooth	39.37" (1 meter) wide	ASTM D6163	SBS modified asphalt base sheet reinforced with a glass fiber mat.
Ruberoid® Mop Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced mop applied SBS base sheet reinforced with a polyester mat.
Ruberoid® Mop Smooth 1.5	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced mop applied SBS base sheet reinforced with a polyester mat.
GAFGLAS® Mineral Surfaced Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with fiberglass mat.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
Tri-Ply® BUR Granule Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with a fiberglass mat.
GAFGLAS® EnergyCap™ Mineral Surface Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with fiberglass mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Topcoat® Surface Seal SB	5 or 55 gallons	ASTM D6083	Solvent based sprayable thermoplastic rubber sealant designed to protect and restore aged roof surfaces and to increase a roof's reflectivity.
Topcoat® Membrane	1, 5 or 55 gallons	ASTM D6083	An acrylic, water based elastomeric membrane system designed to protect various types of roofing surfaces.
Topcoat® MB Plus	5 or 55 gallons	Proprietary	Water based, low VOC primer used to block asphalt bleed-through.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard™ Perlite Roof Insulation	Perlite insulation board.	GAF
EnergyGuard™ Perlite Recover Board	Perlite recover board	GAF
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RN Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH Polyiso Insulation	Polyisocyanurate foam insulation	GAF
DensDeck® Roof Board	Gypsum Board	Georgia-Pacific Gypsum LLC
DensDeck® Prime® Roof Board	Gypsum Board	Georgia-Pacific Gypsum LLC
Structodek® High Density Fiber Board	High Density Fiber board	Blue Ridge FiberBoard, Inc.
Securock® Gypsum-Fiber Roof Board	Gypsum roof board	USG Corporation



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec™ Base Sheet Fastener (1.2 in.)	G-90 galvanized fastener with plate for base sheet attachment to gypsum decks and on lightweight insulating concrete decks less than 2" thick. Coated with CR-10 fluorocarbon coating.	1.2 in.	GAF
2.	Drill-Tec™ Base Sheet Fastener E (1.2 in.)	G-90 galvanized fastener with plate for base sheet attachment to gypsum decks and on lightweight insulating concrete decks less than 2" thick. Coated with CR-10 fluorocarbon coating.	1.2 in.	GAF
3.	Drill-Tec™ Locking Impact Nail	Base sheet fastener with integrated Plate.	1.8" long w/ 2.7" dia. plate	GAF
4.	Drill-Tec™ LD Fastener	Carbon steel fastener for insulation attachment in gypsum and cementitious wood fiber decks. CR-10 coated.	0.240" to 0.375" x 12" max. length	GAF
5.	Drill-Tec™ LD Plate	Round, Galvalume® plate for use with Drill-Tec™ LD Fasteners.	3" Round	GAF



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corporation	0D0A8.AM	4470	07/09/97
	2B8A4.AM	4470	07/02/97
	3042887	4470	11/14/11
Trinity Engineering	#4483.04.97-1	TAS 114	06/06/97
UL LLC	R1306	UL 790	07/22/13
Trinity ERD	G6850.08.07-1	ASTM D3909	08/13/07
	G34140.04.11-4	ASTM D4601	04/25/11
	G30250.02.10-3-R1	ASTM D3909	11/26/12
	G34140.04.11-5	ASTM D4897	04/25/11
	G34140.04.11-5-R1	ASTM D4897	10/18/13
	G34140.04.11-2	ASTM D6163	04/25/11
	G31360.03.10	ASTM D6164	03/31/10
	G33470.01.11	ASTM D6164	01/13/11
	G40630.01.14-1	ASTM D6163	01/06/14
	G40630.01.14-2A	ASTM D6164	01/07/14
	G40630.01.14-2A-1	ASTM D6164	01/07/14
	G43610.01.14	ASTM D3909	01/22/14
	PRI Construction Materials Technologies, LLC	GAF-082-02-01	ASTM D6083
GAF-084-02-01		ASTM D6083	05/07/06
GAF-314-02-01		ASTM D2178	08/23/11
GAF-315-02-01		ASTM D2178	08/23/11
GAF-209.211-02-01		ASTM D6083	05/05/09
GAF-369-02-01		ASTM D1622	10/22/12
GAF-499-02-01		ASTM D6083	03/12/14
GAF-500-02-01		ASTM D6083	03/12/14
GAF-559-02-06		TAS 114	10/16/14
IRT-Arcon, Inc.	02-011	TAS 114	02/26/02
	02-015	TAS 114	03/26/02
Momentum Technologies, Inc.	EX14A3A	ASTM D6083	03/20/03
	AX04C9A	ASTM D6164	06/05/09



APPROVED ASSEMBLIES

- Membrane:** BUR
- Deck Type 6I:** Poured Gypsum, Insulated
- Deck Description:** Poured Gypsum Concrete
- System Type A:** All insulation layers are adhered, to a mechanically attached anchor/base-sheet. Membrane is subsequently fully or partially adhered to insulation.

All General and System Limitations apply.

- Anchor sheet:** One ply of GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Nailable Venting Base Sheet or Ruberoid® 20 Smooth mechanically fastened as described below:
- Fastening Options:**
 - Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 2" side lap 9" o.c. and in two rows staggered in the center of the sheet 12" o.c.;
(Maximum Design Pressure –50 psf. See General Limitation #9)
 - Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 2" side lap 9" o.c. and in three rows staggered in the center of the sheet 9" o.c.;
(Maximum Design Pressure –57.5 psf. See General Limitation #9)
 - Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 4" side lap 7" o.c. and in three rows staggered in the center of the sheet 7" o.c.;
(Maximum Design Pressure –52.5 psf. See General Limitation #7)
 - Drill-Tec™ Locking Impact Nail fasteners at a 4" side lap 9" o.c. and in two rows staggered in the center of the sheet 12" o.c.;
(Maximum Design Pressure –75 psf. See General Limitation #7)

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, Minimum 1.3" thick	N/A	N/A
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.4" thick	N/A	N/A
EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
EnergyGuard™ RA Polyiso Insulation Minimum 1.75" thick	N/A	N/A
EnergyGuard™ Perlite Roof Insulation, EnergyGuard™ Perlite Recover Board, Structodek® High Density Fiberboard Minimum ½" thick	N/A	N/A



Insulation Layer (Continued)

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

**Dens Deck[®] Roof Board, DensDeck[®] Prime[®] Roof Board, Securock[®] Gypsum-Fiber Roof Board
Minimum ¼" thick**

N/A

N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down. GAF requires either a ply of GAFGLAS[®] Stratavent[®] Perforated Venting Base Sheet laid dry or a layer of EnergyGuard[™] Perlite Roof Insulation or wood fiber overlay board on all polyisocyanurate insulation applications.

Base Sheet: One or more plies of GAFGLAS[®] Ply 4, Tri-Ply[®] Ply 4, GAFGLAS[®] FlexPly[™] 6, GAFGLAS[®] #75 Base Sheet, Tri-Ply[®] #75 Base Sheet, GAFGLAS[®] #80 Ultima[™] Base Sheet adhered to the insulation in a full mopping of an approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See General Limitation #4)

OR

GAFGLAS[®] Stratavent[®] Perforated Venting Base Sheet loose laid dry.

Ply Sheet: One or more plies GAFGLAS[®] Ply 4, Tri-Ply[®] Ply 4, GAFGLAS[®] Flex Ply[™] 6 or GAFGLAS[®] #80 Ultima[™] Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Cap Sheet: One ply of GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] BUR Granule Cap Sheet or GAFGLAS[®] EnergyCap[™] Mineral Surface Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.
3. Fibered Aluminum Roof Coating.

**Maximum Design
Pressure:**

See Fastening above.



Membrane: BUR
Deck Type 6: Poured Gypsum Concrete, Non-insulated
Deck Description: Poured gypsum concrete.
System Type E: Anchor sheet is mechanically attached to roof deck.

All General and System Limitations apply.

Base Sheet: One ply of GAFGLAS® FlexPly™ 6, GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Nailable Venting Base Sheet or Ruberoid® 20 Smooth mechanically fastened as described below:

Fastening Options: Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 2" side lap 9" o.c. and in two rows staggered in the center of the sheet 12" o.c.;
(Maximum Design Pressure –50 psf. See General Limitation #9)

Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 2" side lap 9" o.c. and in three rows staggered in the center of the sheet 9" o.c.;
(Maximum Design Pressure –57.5 psf. See General Limitation #9)

Drill-Tec™ Base Sheet Fasteners (1.2 in.) or Drill-Tec™ Base Sheet Fasteners E (1.2 in.) at a 4" side lap 7" o.c. and in three rows staggered in the center of the sheet 7" o.c.;
(Maximum Design Pressure –52.5 psf. See General Limitation #7)

Drill-Tec™ Locking Impact Nail fasteners at a 4" side lap 9" o.c. and in two rows staggered in the center of the sheet 12" o.c.;
(Maximum Design Pressure –75 psf. See General Limitation #7)

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6 or GAFGLAS® #80 Ultima™ Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Cap Sheet: (Optional) One ply of GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® BUR Granule Cap Sheet or GAFGLAS® EnergyCap™ Mineral Surface Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.
3. Fibered Aluminum Roof Coating.

Maximum Design Pressure: See Fastening Above.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida Registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 13-1022.17
Expiration Date: 12/11/18
Approval Date: 02/26/15
Page 9 of 9

