



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

GAF

**1 Campus Dr.
Parsippany, NJ 07054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: HydroStop® PremiumCoat® System over Recover Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No.14-0211.06 and consists of pages 1 through 24.
The submitted documentation was reviewed by Gaspar J Rodriguez.



NOA No.: 16-0308.05
Expiration Date: 05/27/19
Approval Date: 11/03/16
Page 1 of 24

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Liquid Applied Membrane
Deck Type: Recover
Material: Elastomeric
Maximum Design Pressure: See specific assemblies herein

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Container Sizes & Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
United Cleaning Concentrate	1 & 5 Gallon	Proprietary	Biodegradable cleaning agent with specific functional ingredients for degreasing and removing soils and biological residues for proper cleaning of roof surfaces.
Acrylex 400 Primer	1 & 5 Gallon	Proprietary	Acrylic latex primer for use over metal, masonry and wood surfaces.
HydroStop® BarrierGuard® Waterproofing	2 & 5 Gallon	Proprietary	Priming and waterproofing compound for masonry surfaces.
SureBond Primer	2 & 5 Gallon	Proprietary	Acrylic primer used for sealing masonry, metal and chalky surfaces.
CleanAct Rinsable Primer	2 & 5 Gallon	Proprietary	Water based, rinseable primer used directly on rubber roof (EPDM) applications.
Adhere-It® II Primer	2 & 5 Gallon	Proprietary	Water based, rinseable primer used directly on rubber roof (EPDM) applications.
TPO Red Primer	5 Gallon	Proprietary	Solvent-based primer for TPO membranes.
UniBase Primer	5 Gallon	Proprietary	Low viscosity, highly penetrating, acrylic polymer primer.
XR-2000 Primer	5 Gallon	Proprietary	Water-based Acrylic primer for Kynar coated metal
Lock-Down Primer	1 & 5 Gallon	Proprietary	Moisture-Cure Urethane Primer For Corrosion Protection On Metal Surfaces
FlexSeal™ Sealant	1 & 5 Gallon or 1 qt. Tube	TAS 139	Solvent-based, elastomeric sealant.
HydroStop® PremiumCoat® Foundation Coat	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a base layer in the PremiumCoat® System.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Container Sizes & Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
HydroStop® PremiumCoat® Fabric	Rolls	Proprietary	Reinforcing fabric for the PremiumCoat® System and/or BarrierGuard®.
HydroStop® PremiumCoat® Butter Grade Flashing	2 & 5 Gallon	Proprietary	Acrylic elastomeric sealant for bridging gaps, filling voids and low lying roof areas.
HydroStop® PremiumCoat® Finish Coat	2 & 5 Gallon	ASTM D6083	Acrylic elastomeric waterproofing compound used as a top layer in the PremiumCoat® System.
HydroStop® TrafficCoat Deck Coating	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a non-skid surfacing layer over the PremiumCoat® System.
GAF 2-Part Roofing Adhesive	1:1 Applicator	Proprietary	A two-part VOC free polyurethane foam adhesive
RUBEROID® Mop Smooth 1.5	39.37" (1 meter) Wide	ASTM D6164 Type 1S	Smooth surfaced mop applied SBS base or ply sheet reinforced with a polyester mat.
RUBEROID® 20 Smooth	39.37" (1 meter) Wide	ASTM D6163 Type 1S	SBS polymer-modified asphalt base or ply sheet reinforced with a fiberglass mat.
RUBEROID® HW Smooth	39.37" (1 meter) Wide	ASTM D6164 Type 1S	Smooth surfaced torch applied SBS base or ply sheet reinforced with a polyester mat.
RUBEROID® HW 25 Smooth	39.37" (1 meter) Wide	ASTM D6163 Type 1S	Smooth surfaced torch applied SBS base or ply sheet reinforced with a fiberglass mat.
Matrix™101 Premium SBS Membrane Adhesive	5 Gallon	ASTM D3019	Squeegee and spray grade modified asphalt adhesive for use in adhering sand surfaced SBS modified bitumen roofing membranes.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
EnergyGuard™ Polyiso Insulation	Polyiso Insulation	GAF
EnergyGuard™ Tapered Polyiso Insulation	Polyiso Insulation	GAF
EnergyGuard™ Ultra Polyiso Insulation	Polyiso Insulation	GAF
EnergyGuard™ Ultra Tapered Polyiso Insulation	Polyiso Insulation	GAF
EnergyGuard™ RA Polyiso Insulation	Polyiso Insulation	GAF
Dens Deck®	Gypsum Board	Georgia Pacific Gypsum, LLC
Dens Deck® Prime	Gypsum Board	Georgia Pacific Gypsum, LLC



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1	Drill-Tec™ 3” Standard Steel Plate	Galvalume® coated steel stress plate for use with approved Drill-Tec™ fasteners.	3" Round	GAF
2	Drill-Tec™ 3” Steel Plate	Round Galvalume® steel stress plate with reinforcing ribs and recessed for use with Drill-Tec™ fasteners.	3" Round	GAF
3	Drill-Tec™ 3 in. Ribbed Galvalume Plate (Flat)	Round Galvalume® plated steel stress plate with reinforcing ribs for use with Drill-Tec™ fasteners.	3" Round	GAF
4	Drill-Tec™ AccuTrac® Flat Plate	A2-SS aluminized steel plate for use with Drill-Tec™ fasteners.	3" square; .017" thick	GAF
5	Drill-Tec™ AccuTrac® Recessed Plate	Galvalume® steel plate with recess for use with Drill-Tec™ fasteners.	3" square; .017" thick	GAF
6	Drill-Tec™ #12 Fastener	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating. Available with a pinch point or drill point.	#12 x 8" max. length, #3 Phillips head.	GAF
7	Drill-Tec™ #14 Fastener	Truss head, self-drilling, pinch point, high thread fastener for use in steel, wood or concrete decks.	#14 x 16" max. length, #3 Phillips head.	GAF
8	Drill-Tec™ ASAP 3S	Drill-Tec #12 Fastener with Drill-Tec 3" Standard Steel Plate.	See components	GAF



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Atlantic & Caribbean Roof Consulting, LLC	09-021	TAS 114	10/28/09
	09-022	TAS 114	10/29/09
	09-023	TAS 114	10/29/09
	11-004	TAS 114	03/21/11
	11-016	TAS 114	04/07/11
	11-019	TAS 114	04/08/11
Trinity ERD	4697.12.00-1	TAS 114	12/07/00
	GAF-SC10845.04.16	TAS 114	04/26/16
	G31360.03.10	ASTM D6164	03/31/10
	G34140.04.11-2	ASTM D6163	04/25/11
	G40630.01.14-1	ASTM D6164	01/06/14
	G40630.01.14-2A	ASTM D6164	01/07/14
	MCRF Letter 4697.12.00-1	TAS 105	05/09/16
	MCRF Letter GAF-SC10845.04.16	TAS 105	04/29/16
PRI Construction Materials Technologies LLC	EATC-013-02-01	ASTM D3019	09/17/14
	GAF-369-02-01	ASTM C1289	10/22/12
	GAF-417-02-01	ASTM C1289	05/28/13
	GAF-464-02-01	ASTM C1289	02/06/14
	GAF-508-02-01	Proprietary	03/12/14
	GAF-559-02-03	TAS 117	10/16/14
	GAF-661-02-01	Proprietary	06/03/16
	GAF-665-02-01	Proprietary	06/03/16
	GAF-629-02-01	ASTM C1289	03/01/16
	GAF-654-02-01	TAS 114	05/19/16
	GAF-658-02-01	Proprietary	06/07/16
	GAF-659-02-01	Proprietary	06/03/16
	GAF-660-02-01	Proprietary	06/03/16
	GAF-662-02-01	Proprietary	06/07/16
	GAF-663-02-01	Proprietary	06/03/16
	GAF-664-02-01	Proprietary	06/03/16
GAF-667-02-01	TAS 139	07/01/16	
GAF-668-02-01	TAS 139	07/01/16	

(Continued on next page)



EVIDENCE SUBMITTED:

PRI Construction Materials Technologies LLC (cont'd)	GAF-671-02-01	TAS 139	07/01/16	
	GAF-674-02-01	Proprietary	06/01/16	
	GAF-675-02-01	Proprietary	06/01/16	
	GAF-676-02-01	Proprietary	06/01/16	
	GAF-678-02-01	Proprietary	07/14/16	
	GAF-679-02-01	Proprietary	06/01/16	
	GAF-680-02-01	Proprietary	06/01/16	
	GAF-687-02-01	ASTM C794	06/06/16	
	GAF-688-02-01	ASTM C794	06/06/16	
	GAF-693-02-01	ASTM D1876	06/22/16	
	GAF-693-02-02	ASTM D1876	06/22/16	
	HSI-007-02-01	ASTM D6083	05/20/16	
	HSI-009-02-01	ASTM D6083	05/20/16	
	HSI-010-02-01	ASTM D6083	03/25/11	
	HSI-011-02-01	ASTM D6083	03/25/11	
	QCP-018-02-01	TAS 114	11/14/14	
	FM Approvals	3000150	FM 4470	09/22/99
		3023606	FM 4470	10/18/06
		3029832	FM 4470	05/11/07
3031350		FM 4470	09/27/07	
3032811		FM 4470	12/11/08	
3038278		FM 4470	11/18/11	
3041005		FM 4470	03/31/11	
3041769		FM 4470	09/27/12	
3042905		FM 4470	01/10/12	
3044541		FM 4470	04/04/12	
3045166		FM 4470	07/24/12	
3046081		FM 4470	02/13/13	
3047636		FM 4470	08/08/13	
3048496		FM 4470	12/19/13	
FM 797-03825-267		FM 4470	07/14/08	
FM 797-09016-267		FM 4470	12/12/13	
FM Letter		FM 4470	12/06/11	
FM Letter 3048066		FM4470	12/13/13	
FM RR204674		FM 4470	03/23/16	
Underwriters Laboratories	TGFU.R26758	UL 790	02/09/16	

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Trinity ERD	SC10845.04.16, Table 3C	C(3), C(4), C(5)	04/26/16



APPROVED ASSEMBLIES:

- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Structural Concrete, Recover over an Existing Granular Surfaced Roof
- System Type A(1):** All layers of insulation are adhered to the existing roof. Membrane is subsequently fully adhered to the insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ RA Polyiso Insulation, Minimum 1.5” thick	N/A	N/A
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ Ultra Tapered Polyiso Insulation Minimum 1” thick	N/A	N/A

Note: Insulation is adhered with GAF 2-Part Roofing Adhesive applied in 2.5” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard (RAS) 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
 HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
 Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -160 psf (See General Limitation #9)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Structural Concrete, Recover over an Existing Granular Surfaced Roof
- System Type A(2):** All layers of insulation are adhered to the existing roof. Membrane is subsequently fully adhered to the insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck® Prime Minimum 1/4” thick	N/A	N/A

Note: Insulation is adhered with GAF 2-Part Roofing Adhesive applied in 2.5” wide ribbons spaced 12” o.c. or with OlyBond 500® or OlyBond 500® Green applied in ¾ - 1.0” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard (RAS) 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -257.5 psf (See General Limitation #9)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Structural Concrete, Recover over an Existing Granular Surfaced Roof System or Smooth Surfaced Built-Up Roof (BUR) System
- System Type A(3):** All layers of insulation are adhered to the existing roof. Membrane is subsequently fully adhered to the insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation Minimum 1” thick	N/A	N/A

Note: Insulation is adhered with OlyBond 500® or OlyBond 500® Green applied in 1” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard (RAS) 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

- Membrane:** HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
- HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
- Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -160 psf (See General Limitation #9)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Gypsum Concrete Roof Deck, Recover over an Existing Granular Surfaced Roof System or Smooth Surfaced Built-Up Roof (BUR) System
- System Type A(4):** All layers of insulation are adhered to the existing roof. Membrane is subsequently fully adhered to the insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation Minimum 1” thick	N/A	N/A

Note: Insulation is adhered with OlyBond 500® or OlyBond 500® Green applied in 1” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard (RAS) 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

- Membrane:** HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
- HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
- Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -160 psf (See General Limitation #9)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Cementitious Wood Fiber Roof Deck, Recover over an Existing Granular Surfaced Roof System or Smooth Surfaced Built-Up Roof (BUR) System
- System Type A(5):** All layers of insulation are adhered to the existing roof. Membrane is subsequently fully adhered to the insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation Minimum 1” thick	N/A	N/A

Note: Insulation is adhered with OlyBond 500® or OlyBond 500® Green applied in 1” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard (RAS) 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -160 psf (See General Limitation #9)



Membrane Type: Liquid Applied Membrane

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 19/32" thick plywood secured 6" o.c. at panel end and intermediate supports with 8d ring shank nails to supports spaced maximum 24" o.c.

*The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 160 lbf. when tested with Drill-Tec™ #12 Fasteners or Drill-Tec #14 Fasteners installed through to the deck in accordance with TAS 105.

System Type C(1): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):

EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation

Minimum 1" thick

**Insulation Fasteners
(Table 3)**

N/A

**Fastener
Density/ft²**

N/A

Top Insulation Layer:

Dens Deck®

Minimum 0.25" thick

**Insulation Fasteners
(Table 3)**

1, 6, 7, 8

**Fastener
Density/ft²**

1:1.33 ft²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal./sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

Maximum Design

Pressure: Meets -60 psf (See General Limitation #7)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 7I:** Recover, Insulated
- Deck Description:** Minimum 15/32" thick plywood secured 6" o.c. at panel end and intermediate supports with 8d ring shank nails to supports spaced maximum 24" o.c.
- *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 180 lbf. when tested with Drill-Tec™ #12 Fasteners or Drill-Tec #14 Fasteners installed through to the deck in accordance with TAS 105.
- System Type C(2):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation Minimum 1" thick	N/A	N/A
Top Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck® Prime Minimum 0.25" thick	1, 6, 7, 8	1:1.33 ft ²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal./sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** Meets -67.5 psf (See General Limitation #7)



Membrane Type: Liquid Applied Membrane

Deck Type 7I: Recover, Insulated

Deck Description: Structural Concrete or Min. 22 ga., 33 ksi, Type B, 1.5 in. deep, wide rib steel deck secured to supports spaced maximum 72 in. o.c. **The thickness of the existing roof assembly as measured from the top of the steel deck ribs to the surface of the roof cover shall be minimum 1”.**

*The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 218 lbf. when tested with Drill-Tec™ #12 Fasteners (steel deck only) or Drill-Tec™ #14 Fasteners (steel or structural concrete deck) installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analysed for allowable deck stress. See Evidence Submitted Table.

System Type C(3): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation Minimum 1.5” thick	1, 2, 3, 4, 5, 6, 7, 8	1:1.45 ft²

Note: Insulation shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Insulation Joint and Base Sheet Lap Treatment Note: Top insulation layer joints or base sheet laps shall be treated as follows. The insulation joints shall not be treated when the optional base sheet is present.

HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints (when the optional base sheet is NOT present) or base sheet seams (when the optional base sheet is present) in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint or seam. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

**Base Sheet:
(Optional)** RUBEROID® Mop Smooth 1.5 or RUBEROID® 20 Smooth is adhered to the insulation with GAF 2-Part Roofing Adhesive applied in a spatter pattern at 3.75 lbs/sq. The minimum 3” wide base sheet side laps are fully hot air welded.

OR

RUBEROID® 20 Smooth is adhered to the insulation with Matrix™ 101 Premium SBS Membrane Adhesive applied at 1.5 – 2.0 gal/sq. The minimum 3” wide base sheet side laps are fully hot air welded.



Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -75 psf (See General Limitation #7)



Membrane Type: Liquid Applied Membrane

Deck Type 7I: Recover, Insulated

Deck Description: Structural Concrete or Min. 22 ga., 33 ksi, Type B, 1.5 in. deep, wide rib steel deck secured to supports spaced maximum 72 in. o.c. **The thickness of the existing roof assembly as measured from the top of the steel deck ribs to the surface of the roof cover shall be minimum 1”.**

* The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 196 lbf. when tested with Drill-Tec™ #12 Fasteners (steel deck only) or Drill-Tec™ #14 Fasteners (steel or structural concrete deck) installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analysed for allowable deck stress. See Evidence Submitted Table.

System Type C(4): All layers of insulation mechanically attached to roof deck. Top insulation layer joints prepared per note below. HydroStop® PremiumCoat® System applied to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):

**EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation
Minimum 1” thick**

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

N/A

N/A

Top Insulation Layer:

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

**Dens Deck® Prime
Minimum ¼” thick**

1, 3, 4, 6, 7, 8

1:1.45 ft²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint and Base Sheet Lap Treatment Note: Top insulation layer joints or base sheet laps shall be treated as follows. The insulation joints shall not be treated when the optional base sheet is present.

HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints (when the optional base sheet is NOT present) or base sheet seams (when the optional base sheet is present) in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint or seam. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.



**Base Sheet:
(Optional)**

RUBEROID® 20 Smooth is adhered to the top insulation layer with Matrix™ 101 Premium SBS Membrane Adhesive applied at 1.5 – 2.0 gal/sq. The minimum 3” wide base sheet side laps are fully hot air welded.

OR

RUBEROID® HW Smooth or RUBEROID® HW 25 Smooth torch adhered to the top insulation layer within minimum 3” wide side laps.

OR

RUBEROID® Mop Smooth 1.5 or RUBEROID® 20 Smooth is adhered to the top insulation layer with GAF 2-Part Roofing Adhesive applied in a spatter pattern at 3.75 lbs/sq. The minimum 3 in. wide base sheet side laps are fully hot air welded.

Membrane:

HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)**

HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:**

Meets -67.5 psf (See General Limitation #7)



Membrane Type: Liquid Applied Membrane

Deck Type 7I: Recover, Insulated

Deck Description: Structural Concrete or Min. 22 ga., 33 ksi, Type B, 1.5 in. deep, wide rib steel deck secured to supports spaced maximum 72 in. o.c. **The thickness of the existing roof assembly as measured from the top of the steel deck ribs to the surface of the roof cover shall be minimum 1”.**

* The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 218 lbf. when tested with Drill-Tec™ #12 Fasteners (steel deck only) or Drill-Tec™ #14 Fasteners (steel or structural concrete deck) installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analysed for allowable deck stress. See Evidence Submitted Table.

System Type C(5): All layers of insulation mechanically attached to roof deck. Top insulation layer joints prepared per note below. HydroStop® PremiumCoat® System applied to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):

**EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation
Minimum 1” thick**

**Insulation Fasteners
(Table 3)**

N/A

**Fastener
Density/ft²**

N/A

Top Insulation Layer:

**SECUROCK® Gypsum-Fiber Roof Board
Minimum ¼” thick**

1, 3, 4, 6, 7, 8

1:1.45 ft²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint and Base Sheet Lap Treatment Note: Top insulation layer joints or base sheet laps shall be treated as follows. The insulation joints shall not be treated when the optional base sheet is present. HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints (when the optional base sheet is NOT present) or base sheet seams (when the optional base sheet is present) in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint or seam. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.



Base Sheet: (Optional)

RUBEROID® 20 Smooth is adhered to the top insulation layer with Matrix™ 101 Premium SBS Membrane Adhesive applied at 1.5 – 2.0 gal/sq. The minimum 3” wide base sheet side laps are fully hot air welded.

OR

RUBEROID® HW Smooth or RUBEROID® HW 25 Smooth is torch adhered to the top insulation layer within minimum 3” wide base sheet side laps.

OR

RUBEROID® Mop Smooth 1.5 or RUBEROID® 20 Smooth is adhered to the top insulation layer with GAF 2-Part Roofing Adhesive applied in a spatter pattern at 3.75 lbs/sq. The minimum 3” wide base sheet side laps are fully hot air welded.

Membrane:

HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)**

HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:**

Meets -75 psf (See General Limitation #7)



Membrane Type: Liquid Applied Membrane

Deck Type 7: Recover, Non-Insulated

Deck Description: Structural Concrete, Recover, min. 1” thick Spray Polyurethane Foam (SPUF) applied over an existing Built-Up Roof (BUR)

System Type F(1): HydroStop® PremiumCoat® System applied to SPUF

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

**Maximum Design
Pressure:** Meets -237.5 psf (See General Limitation #9)



Membrane Type: Liquid Applied Membrane
Deck Type 7: Recover, Non-Insulated
Deck Description: Recover over an Existing Spray Polyurethane Foam Roof (SPUF)
System Type F(2): HydroStop® PremiumCoat® System applied to SPUF

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq. HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq. Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** (As determined by TAS 124)

Membrane Type: Liquid Applied Membrane
Deck Type 7: Recover, Non-Insulated
Deck Description: Recover over an Existing TPO Roof System
System Type F(3): HydroStop® PremiumCoat® System applied to existing TPO

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Primer: TPO Red Primer is applied at 0.5 gal./sq.
Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq. HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq. Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** (As determined by TAS 124)



Membrane Type: Liquid Applied Membrane
Deck Type 7: Recover, Non-Insulated
Deck Description: Recover over an Existing PVC Roof System
System Type F(4): HydroStop® PremiumCoat® System applied to existing PVC

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** (As determined by TAS 124)

Membrane Type: Liquid Applied Membrane
Deck Type 7: Recover, Non-Insulated
Deck Description: Recover over an Existing EPDM Roof System
System Type F(5): HydroStop® PremiumCoat® System applied to existing EPDM

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** (As determined by TAS 124)



Membrane Type: Liquid Applied Membrane

Deck Type 7: Recover, Non-Insulated

Deck Description: Recover over an Existing Built-Up Roof (BUR) or Modified Bitumen Roof

System Type F(6): HydroStop® PremiumCoat® System applied to existing BUR or modified bitumen roof cover.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** (As determined by TAS 124)

MANUFACTURER'S REQUIREMENTS:

1. Contractor must be a GAF HydroStop® "Approved Applicator", trained and familiar with the details and specifications published by the manufacturer. Proof of this qualification shall be provided in written form from the manufacturer.
2. Refer to GAF's published installation instructions for detailed installation requirements and recommendations.
3. HydroStop® TrafficCoat Deck Coating is required for traffic bearing surfaces: All pedestrian traffic areas shall be coated with HydroStop® TrafficCoat Deck Coating as non-skid surfacing.

RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.
2. All assemblies listed herein shall be installed in compliance with the applicable sections of FBC 1521. Uplift performance of assemblies bonded to existing roofing system shall be verified per 1521.10. Uplift performance of assemblies mechanically attached through existing roofing system shall be verified per 1521.11.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt and/or adhesives panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant
(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

