



QUICK SPEC

WARRANTY EXTENSION/ RENEWAL – HYDROSTOP® PREMIUMCOAT®

NOTE: The following “Quick Spec” is an abbreviated specification and is not meant to replace the detailed specification. Read the entire 3-Part CSI System Specification prior to starting the project.

- Method**
- Spray, roller, or brush apply HydroStop® PremiumCoat® Finish Coat
- Requirements**
- The existing HydroStop® Roofing System will be inspected to determine eligibility for recoat.
 - Roof must be clean, dry, and tight.
 - Adhesion test required to ensure proper adhesion to substrate(s).
 - Apply at 50°F (10°C) and rising with no rain, dew, fog or freezing temperatures in forecast for 24 hours.
 - GAF recommends that the surface temperature be at or less than 110°F (43°C) during application.
- Application Instructions**
1. Roof must be inspected before work begins.
 2. Ensure roof is free of dirt, debris, oil, and other contaminants that could negatively affect adhesion
 3. Apply HydroStop® PremiumCoat® Finish Coat per the chart below.

WARRANTY EXTENSION/RENEWAL HYDROSTOP® PREMIUMCOAT® SYSTEM						
Warranty Term	Finish Coat				Warranty	
	1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	Emerald Pledge™	Diamond Pledge™
10 Year	0.75	0.75	1.5	13	Yes	Yes
15 Year	1.0	1.0	2.0	17		

* DFT (Dry Film Thickness) is rounded to nearest mil. Actual DFT will vary dependent on substrate profile, application technique & waste factor. Primer/Base is not included in DFT calculations.