



# QUICK SPEC

## ROOF MATE + KYMAX

### METAL

**NOTE:** The following "Quick Spec" is an abbreviated specification and is not meant to replace the detailed specification. Read the entire 3-Part CSI System Specification prior to starting the project.

- |                                 |  |
|---------------------------------|--|
| <b>Method</b>                   | <ul style="list-style-type: none"> <li>Spray, roller, or brush</li> </ul>  |
| <b>Requirements</b>             | <ul style="list-style-type: none"> <li>Roof must be clean, dry, and tight.</li> <li>Adhesion test required to ensure proper adhesion to substrate(s).</li> <li>Apply at 50°F (10°C) and rising with no rain, dew, fog or freezing temperatures in forecast for 24 hours.</li> <li>GAF recommends that the surface temperature be at or less than 105°F (40°C) during application.</li> </ul>   |
| <b>Application Instructions</b> | <ol style="list-style-type: none"> <li>Tighten and/or replace existing fasteners.</li> <li>Power-wash roof to ensure it is free of dirt, debris, oil, and other contaminants that could negatively affect adhesion. United Cleaning Concentrate (UCC) is recommended to clean the roof. Allow roof to completely dry.</li> <li>Install crickets to divert water and complete other necessary sheet metal repairs.</li> <li>Prime rusty areas with Acrylex 400 Primer. For severe rust, prime area with Lock-Down Primer.</li> <li>Treat all seams.</li> <li>Treat all roof penetrations, skylight curbs &amp; rake edges.</li> <li>Encapsulate fasteners.</li> <li>Apply coating per the chart below:</li> </ol> |

METAL - SEAMS										
ROOF MATE + KYMAX™										
Warranty Term	Seam Type	Product	Total (Gal/Sq)	DFT* (mils)	Kymax™				System	
					1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	Total (Gal/Sq)	DFT* (mils)
15 & 20 Year	Horizontal Seam** (W/Fabric)	Roof Mate Butter Grade	4.00	41	0.40	0.40	0.80	4.5	4.80	45.5
	Vertical Seam (No Fabric)	Roof Mate Butter Grade	4.00	35	0.40	0.40	0.80	4.5	4.80	39.8

\*\* DFT at horizontal seams includes 6 mils for the fabric.

METAL														
ROOF MATE + KYMAX™														
Warranty Term	Roof Mate						Kymax™				System		Warranty	
	Product (Choose one)	1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	3rd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	Total (Gal/Sq)	DFT* (mils)	Emerald Pledge™	Diamond Pledge™
15 year <sup>+</sup>	Roof Mate & QS	1.00	1.50		2.50	21	0.40	0.40	0.80	4.5	3.30	25.5	Yes	Yes
	Roof Mate HT	1.00	1.50		2.50	21					3.30	25.5		
	Roof Mate TCM	1.00	1.00		2.00	19					2.80	23.5		
20 year <sup>+</sup>	Roof Mate & QS	1.00	1.50	1.00	3.50	30	0.40	0.40	0.80	4.5	4.30	34.5	Yes	Yes
	Roof Mate HT	1.00	1.50	1.00	3.50	29					4.30	33.5		
	Roof Mate TCM	1.50	1.75		3.25	30					4.05	34.5		

\* Actual DFT will vary dependent on substrate profile, application technique & waste factor.

<sup>+</sup>Eligible for 10 year Extended Limited Warranty (color).