



QUICK SPEC

ROOF MATE + KYMAX

STRUCTURAL CONCRETE & CORRUGATED STRUCTURAL TRANSITE PANEL

NOTE: The following "Quick Spec" is an abbreviated specification and is not meant to replace the detailed specification. Read the entire 3-Part CSI System Specification prior to starting the project.

- | | |
|---------------------------------|--|
| Method | <ul style="list-style-type: none"> Spray, roller, or brush |
| Requirements | <ul style="list-style-type: none"> Moisture survey recommended. Roof must be clean, dry, and tight. Adhesion test required to ensure proper adhesion to substrate(s). Apply at 50°F (10°C) and rising with no rain, dew, fog or freezing temperatures in forecast for 24 hours. GAF recommends that the surface temperature be at or less than 105°F (40°C) during application. Concrete must be fully cured (typically 28 days). |
| Application Instructions | <ol style="list-style-type: none"> Conduct moisture survey to ensure concrete contains less than 8% moisture. Repair or replace damaged or deteriorated sections with like materials, allowing cementitious products to cure properly. Power-wash roof. United Cleaning Concentrate (UCC) is recommended to clean the roof. Allow the roof to completely dry. Prime with Epoxy Primer. Treat all seams. Treat structural joints with backer rod and urethane or silicone sealant, then treat with Roof Mate Butter Grade Flashing and Roof Mate Fabric. Treat all roof penetrations, drains, curbs, and scuppers with Roof Mate Butter Grade Flashing and Roof Mate Fabric. Apply coating per the chart below: |

STRUCTURAL CONCRETE & CORRUGATED STRUCTURAL TRANSITE PANEL													
ROOF MATE + KYMAX™													
Warranty Term	Roof Mate					Kymax™				System		Warranty	
	Product (Choose One)	1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	1st Coat (Gal/Sq)	2nd Coat (Gal/Sq)	Total (Gal/Sq)	DFT* (mils)	Total (Gal/Sq)	DFT* (mils)	Emerald Pledge™	Diamond Pledge™
15 year†	Roof Mate & QS	1.50	1.50	3.00	26	0.40	0.40	0.80	4.5	3.80	30.5	Yes	No
	Roof Mate HT	1.50	1.50	3.00	25					3.80	29.5		
	Roof Mate MB Plus	1.50	1.50	3.00	26					3.80	30.5		
	Roof Mate TCM	1.50	1.50	3.00	29					3.80	33.5		

*Actual DFT will vary dependent on substrate profile, application technique & waste factor.

†Eligible for 10 year Extended Limited Warranty (color).

NOTE: Corrugated Structural Transite Panels may contain asbestos. Follow all applicable local, state and federal regulations concerning asbestos. Under no circumstances does GAF have any liability for any damages, costs or expenses arising out of or associated with the pre-existing presence of asbestos-containing materials or any other allegedly hazardous substances or materials on the roof to which the new GAF roofing materials are being applied.