



NOTE:

1. RREFER TO THE MECHANICALLY FASTENED PURLIN ATTACHMENT TABLE FOR ADDITIONAL INFORMATION.
2. INSULATION BOARDS INSTALLED IN SINGLE OR MULTIPLE LAYERS MUST HAVE THE JOINTS BETWEEN THE BOARDS STAGGERED IN ALL DIRECTIONS A MINIMUM OF 6" (152 mm) BETWEEN LAYERS.
3. PRELIMINARY FASTENING MAY BE REQUIRED.

GAF

PURLIN ASSEMBLY - FASTENERS LOCATED IN SEAMS

DRAWING #
100G

THIS DETAIL APPLIES TO:
MECHANICALLY ATTACHED SYSTEMS

ISSUE / REVISION DATE
8/17/20

SCALE
N.T.S.

LEGEND

 HEAT-WELDED