

**NOTE:**

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.
2. TERMINATION BAR MUST BE FASTENED 6" (152 mm) O.C. FOR THIS DETAIL.

GAF**MEMBRANE AT ROOF EDGE WITH TERMINATION BAR**DRAWING #
208THIS DETAIL APPLIES TO:
ADHERED SYSTEMS
FLASHING/OND SYSTEMS
SELF-ADHERED SYSTEMS
MECHANICALLY ATTACHED SYSTEMSISSUE / REVISION DATE
8/24/20SCALE
N.T.S.**LEGEND** FLEXSEAL™ CAULK GRADE SEALANT