



NOTE:

- 1. A FIELD WELD CANNOT PASS WITHIN 9" (229 mm) OF THE CLAMPING, OR WITHIN THE DRAIN SUMP ITSELF.
- 2. MEMBRANE MUST EXTEND MINIMUM 1" (25.4 mm) BEYOND THE BOLT HOLES; THE CLAMPING RING BOLTS MUST PENETRATE THE MEMBRANE.
- 3. TAPER INSULATION TO CREATE A ROOF SUMP MINIMUM 36" x 36" (0.914 m x 0.914 m) IN SIZE IF APPLICABLE.
- 4. IF ASPHALT OR ASPHALTIC PRODUCT IS PRESENT, STOP AT BEGINNING OF SUMP AND FLASH WITH SMOOTH TPO.
- 5. DO NOT RUN SEPARATION SHEET INTO BOWL AREA IF USED IN SYSTEM.



DRAIN - POST TARGET

| | | | |
|-----------|-------------------------|-----------------------|--------|
| DRAWING # | THIS DETAIL APPLIES TO: | ISSUE / REVISION DATE | SCALE |
| 520 | ALL SYSTEMS | 8/17/20 | N.T.S. |

LEGEND

- HEAT-WELDED
- EVERGUARD® WATER-BLOCK OR FLEXSEAL™ CAULK GRADE SEALANT