



#### NOTES:

1. EDGE METAL SHOULD BE DESIGNED FOR WIND RESISTANCE IN ACCORDANCE WITH THE APPLICABLE EDITION OF ASCE 7. ADDITIONAL REQUIREMENTS APPLY FOR GUARANTEE COVERAGE OF ATTACHMENT TO INSULATED METAL WALL PANELS. CONTACT [coldstorage.assistance@gaf.com](mailto:coldstorage.assistance@gaf.com) FOR DETAILS.
2. FOR STEEL ROOF DECKS: FILL STEEL DECK FLUTES WITH CLOSED CELL SPRAY FOAM INSULATION PRIOR TO THE INSTALLATION OF ABOVE DECK INSULATION A MINIMUM OF 12" [305 mm] FROM FACE OF WALL.

## Preparation of IMP Walls for Edge Termination



We  
protect  
what  
matters  
most™

#### Legend:

Sealant



Adhesive



Foam



#### Product:

EverGuard PVC

#### Installation:

Cold Storage  
Systems

#### Maximum

Warranty:

—

#### Date:

9/12/2025

#### Scale:

Not To Scale

#### Detail No.

075419

**237**