

EVERGUARD® UTILITY FLASHING MEMBRANE OR MIN. 8" WIDE REINFORCED
EVERGUARD® TPO OR PVC MEMBRANE

REINFORCED EVERGUARD® MEMBRANE

6" MIN.

1" MIN.

FLANGE FASTENED 12" O.C. MIN.

CONTINUOUS BEAD OF SEALANT
BELOW METAL PANEL CAP (BY
OTHERS)

OPTIONAL RAISED EDGE

EVERGUARD® COATED EDGE
METAL WITH CONTINUOUS CLIP
FASTENED 12" O.C. MIN.

SEE ROOF ASSEMBLY DETAIL FOR SYSTEM INFORMATION

MULTIPLE LAYERS OF ENERGYGUARD™ POLYISO
INSULATION STAGGERED AND OFFSET

POCKETS FILLED WITH GAF SPF FLASHING

THERMAL CUT IN I.M.P. SKIN

OPTIONAL GUTTER

INSULATED METAL PANEL WITH
METAL CAP (BY OTHERS)

NOTES:

1. EDGE METAL SHOULD BE DESIGNED FOR WIND RESISTANCE IN ACCORDANCE WITH THE APPLICABLE EDITION OF ASCE 7. ADDITIONAL REQUIREMENTS APPLY FOR GUARANTEE COVERAGE OF ATTACHMENT TO INSULATED METAL WALL PANELS. CONTACT coldstorage.assistance@gaf.com FOR DETAILS.
2. FOR STEEL ROOF DECKS: FILL STEEL DECK FLUTES WITH CLOSED CELL SPRAY FOAM INSULATION PRIOR TO THE INSTALLATION OF ABOVE DECK INSULATION A MINIMUM OF 12" FROM FACE OF WALL ON EACH SIDE.



**We
protect
what
matters
most™**

Legend:

Heat Weld



Sealant



Adhesive



Foam



Product:

EverGuard TPO

Installation:

Cold Storage
Systems

Maximum Warranty:

—

Date:

2/14/2025

Scale:

Not To Scale

Detail No.

075423

201C

Coated Drip Edge with Flashing Strip at IMP