



Foam

311A



1. FOR STEEL ROOF DECKS: FILL STEEL DECK FLUTES WITH CLOSED CELL SPRAY FOAM INSULATION PRIOR TO THE INSTALLATION OF ABOVE DECK INSULATION A MINIMUM OF 12" [305 mm] FROM FACE OF WALL ON EACH SIDE.
2. ALL (4) ROOF-SIDE CORNERS OF SCUPPER MUST BE COMPLETELY SEALED USING EVERGUARD® UNREINFORCED DETAILING MEMBRANE OR EVERGUARD® PREFORMED CORNER ACCESSORIES.
3. SCUPPER MUST BE SEALED OFF ON EXTERIOR FACE OF BUILDING.

1 Campus Drive, Parsippany NJ 07054 | Toll Free 877.423.7664 | gaf.com