



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

GAF

**1 Campus Dr.
Parsippany, NJ 07054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: HydroStop® PremiumCoat® System over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 16-0308.03 and consists of pages 1 through 9.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 18-1105.04
Expiration Date: 01/01/24
Approval Date: 01/03/19
Page 1 of 9

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Liquid Applied Roof Systems
Deck Type:	Wood
Material:	Elastomeric
Maximum Design Pressure:	-67.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
United Cleaning Concentrate	1 & 5 Gallon	Proprietary	Biodegradable cleaning agent with specific functional ingredients for degreasing and removing soils and biological residues for proper cleaning of roof surfaces.
HydroStop® BarrierGuard® Waterproofing	2 & 5 Gallon	Proprietary	Priming and waterproofing compound for masonry surfaces.
SureBond Primer	2 & 5 Gallon	Proprietary	Acrylic primer used for sealing masonry, metal and chalky surfaces.
UniBase Primer	5 Gallon	Proprietary	Low viscosity, highly penetrating, acrylic polymer primer.
Lock-Down Primer	1 & 5 Gallon	Proprietary	Moisture-Cure Urethane Primer For Corrosion Protection On Metal Surfaces.
XR-2000 Primer	5 Gallon	Proprietary	Water-based Acrylic primer for Kynar coated metal
Acrylex 400 Multisurface Roof Primer	1 & 5 Gallon	Proprietary	Acrylic latex primer for use over metal, masonry and wood surfaces.
FlexSeal™ Sealant	1 & 5 Gallon or 1 qt. Tube	TAS 139	Solvent-based, elastomeric sealant.
HydroStop® PremiumCoat® Foundation Coat	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a base layer in the PremiumCoat® System.
HydroStop® PremiumCoat® Fabric	Rolls	Proprietary	Reinforcing fabric for the PremiumCoat® System and/or BarrierGuard®.
HydroStop® PremiumCoat® Butter Grade Flashing	2 & 5 Gallon	Proprietary	Acrylic elastomeric sealant for bridging gaps, filling voids and low lying roof areas.
United Coatings™ Roof Mate TCM Flashing	2 & 5 Gallon	TAS 139	Water based, high solids, elastomeric sealant.
United Coatings™ Roof Mate Liquid Fabric	5 & 55 Gallon	TAS 139	Water based, sprayable highly elastic flashing compound.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
HydroStop® PremiumCoat® Finish Coat	2 & 5 Gallon	ASTM D6083	Acrylic elastomeric waterproofing compound used as a top layer in the PremiumCoat® System.
HydroStop® TrafficCoat Deck Coating	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a non-skid surfacing layer over the PremiumCoat® System.
GAFGLAS® Stratavent® Nailable Venting Base Sheet	39-3/8" wide	ASTM D4897, Type II	Smooth surfaced, asphaltic, nailable venting base sheet reinforced with fiberglass mat. Bottom side surfaced with granules.
VersaShield® Solo™ Fire-Resistant Slip Sheet	6' wide Rolls	Proprietary	Non-asphaltic, fire resistant fiberglass underlayment.
FireOut™ Fire Barrier Coating	5 or 55 Gallons	Proprietary	Low VOC, water-based fire barrier coating.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
DensDeck® Roof Board	Gypsum Board	Georgia Pacific Gypsum LLC
DensDeck® Prime Roof Board	Gypsum Board	Georgia Pacific Gypsum LLC



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec™ 3" Standard Steel Plate	Galvalume® coated steel stress plate for use with approved Drill-Tec™ fasteners.	3" Round	GAF
2.	Drill-Tec™ #14 Fastener	Truss head, self-drilling, pinch point, high thread fastener for use in steel, wood or concrete decks.	#14 x 16" max. length, #3 Phillips head.	GAF
3.	Drill-Tec™ #12 Fastener	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating. Available with a pinch point or drill point.	#12 x 8" max. length, #3 Phillips head.	GAF
4.	Drill-Tec™ ASAP 3S	Drill-Tec #12 Fastener with Drill-Tec 3" Standard Steel Plate.	See components	GAF



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Atlantic & Caribbean Roof Consulting, LLC	10-001	TAS 114	02/10/10
PRI Construction Materials Technologies, LLC	GAF-270-02-02	ASTM D146	10/06/10
	GAF-306-02-01	ASTM E96	08/23/11
	GAF-349-02-01	ASTM D146	05/29/18
	GAF-369-02-01	ASTM C1289	10/22/12
	GAF-464-02-01	ASTM C1289	02/06/14
	GAF-559-02-03	TAS 117	10/16/14
	GAF-629-02-01	ASTM C1289	03/01/16
	GAF-658-02-01	Proprietary	06/07/16
	GAF-659-02-01	Proprietary	06/03/16
	GAF-661-02-01	Proprietary	06/03/16
	GAF-662-02-01	Proprietary	06/07/16
	GAF-660-02-01	Proprietary	06/03/16
	GAF-664-02-01	Proprietary	06/03/16
	GAF-665-02-01	Proprietary	06/03/16
	GAF-667-02-01	TAS 139	07/01/16
	GAF-668-02-01	TAS 139	07/01/16
	GAF-671-02-01	TAS 139	07/01/16
	GAF-674-02-01	Proprietary	06/01/16
	GAF-675-02-01	Proprietary	06/01/16
	GAF-676-02-01	Proprietary	06/01/16
	GAF-678-02-01	Proprietary	07/14/16
	GAF-679-02-01	Proprietary	06/01/16
	GAF-680-02-01	Proprietary	06/01/16
	GAF-693-02-01	ASTM D1876	06/22/18
	GAF-754-02-01	Proprietary	06/19/17
	GAF 777-02-01REV	ASTM D6083	09/18/17
HSI-007-02-01	ASTM D6083	05/20/16	
HSI-009-02-01	ASTM D6083	05/20/16	
QCP-018-02-01	TAS 114	11/14/14	
Trinity ERD	4697.12.00-1	TAS 114	12/07/00
	G34140.04.11-5-R3	ASTM D4897	06/04/15
UL LLC	08CA37926	UL 790	09/23/09
	08CA49140	UL 790	09/23/09
	TGFU.R26758	UL 790	02/09/16



APPROVED ASSEMBLIES:

- Membrane Type:** Liquid Applied Membrane
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Minimum 19/32” thick plywood secured 6” o.c. at panel end and intermediate supports with 8d ring shank nails to supports spaced maximum 24” o.c.
- System Type C(1):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer’s specifications. The following are minimum installation guidelines. Consult the manufacturer’s specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation Minimum 1” thick	N/A	N/A
Top Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Roof Board Minimum 0.25” thick	1, 2	1:1.33 ft ²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal/sq.

- Membrane:** HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.
HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.
Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

Surfacing:
(Optional) HydroStop® TrafficCoat Deck Coating applied per manufacturer’s installation instructions.

Maximum Design Pressure: -60 psf (See General Limitation #7)



Membrane Type: Liquid Applied Membrane

Deck Type 1I: Wood, Insulated

Deck Description: Minimum 15/32" thick plywood secured 6" o.c. at panel end and intermediate supports with 8d ring shank nails to supports spaced maximum 24" o.c.

System Type C(2): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

One or more layers of the following insulations.

Base Insulation Layer (Optional):	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation Minimum 1" thick	N/A	N/A
Top Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Prime Roof Board Minimum 0.25" thick	1, 2, 3, 4	1:1.33 ft ²

Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Joint Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all top insulation layer joints in a 6 in. width at a rate of 1.25 gal./sq. centered about each joint. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal./sq.

Membrane: HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq.

HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

**Maximum Design
Pressure:** -67.5 psf (See General Limitation #7)



- Membrane Type:** Liquid Applied Membrane
- Deck Type 1:** Wood, Non-Insulated
- Deck Description:** Minimum 19/32" thick plywood secured 6" o.c. at panel end and intermediate supports with 8 ring shank nails to supports spaced maximum 24" o.c.
- System Type E:** Anchor sheet mechanically attached to roof deck. Membrane is subsequently fully adhered to anchor sheet.

HydroStop® PremiumCoat® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System Limitations apply.

- Fire Barrier:** VersaShield® SOLO™ Fire Reistant Slip Sheet or FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.
- Anchor Sheet:** GAFGLAS® Stratavent® Nailable Venting Base Sheet is secured to the deck with Miami-Dade County Approved annular ring shank nails and 1-5/8" diameter tin caps spaced 7" o.c. along the 4" wide anchor sheet side laps and 7" o.c. in two staggered rows in the field of the sheet.

Anchor Sheet Lap Treatment Note: HydroStop® PremiumCoat® Foundation Coat is brush applied over all anchor sheet laps in a 6 in. width at a rate of 1.25 gal./sq. centered about each lap. 6 in. wide HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat. The fabric is then saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at 1.25 gal./sq.

- Membrane:** HydroStop® PremiumCoat® Foundation Coat is brush applied at a minimum rate of 1.25 gal./sq. HydroStop® PremiumCoat® Fabric is embedded in the wet HydroStop® PremiumCoat® Foundation Coat base coat within 4 in. wide seams and is saturated with additional HydroStop® PremiumCoat® Foundation Coat brush applied at a minimum rate of 1.25 gal./sq. Two (2) or more coats of HydroStop® PremiumCoat® Finish Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

- Surfacing:** HydroStop® TrafficCoat Deck Coating applied per manufacturer's installation instructions.

- Maximum Design Pressure:** -45 psf (See General Limitation #7)

MANUFACTURER'S REQUIREMENTS:

1. Contractor must be a GAF HydroStop® "Approved Applicator", trained and familiar with the details and specifications published by the manufacturer. Proof of this qualification shall be provided in written form from the manufacturer.
2. Refer to GAF's published installation instructions for detailed installation requirements and recommendations.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt and/or adhesives panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

