



**NOTE:**

1. MINIMUM SLOPE IS 2:12.
2. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICAL SYSTEMS ONLY.
3. ADD BALLAST PER SPECIFICATION FOR BALLASTED SYSTEMS.
4. FOR SELF-ADHERED SYSTEMS, SEE EVERGUARD® DETAIL 330 FOR LAP APPLICATION.
5. APPLY EVERGUARD® TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES (REFER TO EVERGUARD® DETAIL 115).



**EverGuard**  
SINGLE-PLY ROOFING SYSTEMS  
ROOF PENETRATION  
SERIES

DRAWING #

**601**

SCALE  
N.T.S.

**STEEP-SLOPE TO LOW-SLOPE  
TRANSITION DETAIL**

THIS DETAIL APPLIES TO:

**ALL SYSTEMS**

www.gaf.com  
1 Campus Drive.  
Parsippany, NJ 07054

REVISION DATE  
1-7-19