


Extend GAF leak barrier at least 5" (127 mm) up wall.

2 nails per step flashing

Place metal step flashing just upslope from exposed edge of shingle and extend 5" (127 mm) over underlying shingle and 5" (127 mm) up the vertical wall.

Step flashing pieces overlap each other 2" (51 mm)



Cover metal flashing with cut shingle. Do NOT nail shingle, install with asphaltic plastic cement.

Extend GAF leak barrier at least 5" (127 mm) up wall

Metal flashing (Nailed to the deck, NOT to the vertical wall) extend up wall at least 5" (127 mm)

Siding/cladding must be at least 2" (51mm) above the roof surface and covering flashing at least 2" (51 mm).



www.gaf.com
1 Campus Drive
Parsippany, NJ
07054

BRAND SERIES

SIENNA SERIES

REVISION DATE

6-01-15

SCALE

N.T.S

WALL FLASHING DETAIL

DETAIL NUMBER

06

DETAIL REFERENCE

SS-SNA