

# PREMIUM ACRYLIC HYDROSTOP® FABRIC REINFORCED QUICK SPEC WARRANTY/GUARANTEE EXTENSION/RENEWAL (HS-21)

**NOTE:** The following "Quick Spec" is an abbreviated specification and is not meant to replace the detailed specification. Complete 3-part CSI System Specifications are available at [www.gaf.com](http://www.gaf.com).



## METHOD REQUIREMENTS

### Required:

- The existing HydroStop® Roofing System must be inspected by GAF's Field Services to determine eligibility for recoat.
- Roof must be clean, dry, and tight.
- Adhesion test required.
- Apply at 50°F (10°C) and rising with no rain, dew, fog or freezing temperatures in the forecast for 8 hours.

### Recommendations:

- Refer to Technical Data Sheet for product specific application and surface temperature restrictions.

### Installation Overview:

1. Roof must be inspected by GAF Field Services before work begins. Any issues found during the inspection must be repaired prior to the application.
2. Before coating is applied, an adhesion test is required to ensure an adhesion minimum of 2.0 pounds per linear inch (PLI). Test patches should be applied with rates listed below.
3. Power wash substrate to remove contaminants that could negatively affect adhesion.
4. Apply coating per the chart below.

### CLEAN/ PRIME

|                | Product                        | Rate (Gal/Sq) |
|----------------|--------------------------------|---------------|
| <b>Cleaner</b> | Cleaning Concentrate (diluted) | 0.5 - 0.7     |
| <b>Primer</b>  | Not required                   | N/A           |

### SEAMS & DETAILS

| Treatment Type            | Product   | Total (Gal/Sq) | Total (linear ft/gal)* | DFT* (mils) |
|---------------------------|---|----------------|------------------------|-------------|
| 3-Coursed Rates           | Premium Brush-Grade Acrylic Flashing and Fabric | 4.0            | 30                     | 43          |
| Flashing Grade Only Rates | Premium Brush-Grade Acrylic Flashing            | 2.0            | 100                    | 19          |

Note: For other product options, please refer to our Seam Treatment Guide.  
<sup>2</sup>Flashing rates are based on a 6" (152 mm) width.

### WARRANTY/GUARANTEE EXTENSION/RENEWAL

|                | Premium Acrylic HydroStop® Top Coat |                   |                |             | Warranties/Guarantees Available |                 |
|----------------|-------------------------------------|-------------------|----------------|-------------|---------------------------------|-----------------|
|                | 1st Coat (Gal/Sq)                   | 2nd Coat (Gal/Sq) | Total (Gal/Sq) | DFT* (mils) | Emerald Pledge™                 | Diamond Pledge™ |
| <b>10 Year</b> | 0.75                                | 0.75              | 1.50           | 13          | Yes                             | Yes             |
| <b>15 Year</b> | 1.00                                | 1.00              | 2.00           | 17          | Yes                             | Yes             |

\* Dry Film Thickness (DFT) is rounded to nearest mil, and is theoretical. Actual DFT will vary dependent on substrate profile, application technique and waste factor.  
 Note: DFT for 3-coursed rates includes 6 mils for the fabric.