



NOTE:

1. MASONRY WALLS TO BE PRIMED PRIOR TO FLASHING. WOOD WALLS REQUIRE BASE SHEET NAILED TO WALL 9" (229 mm) O.C. ALONG TOP AND LAPS, ONE FASTENER EVERY SQUARE FOOT IN THE FIELD.
2. WALL COVERINGS TURNED OVER EDGE A MINIMUM OF 1 1/2" (38 mm) OR THICKNESS OF NAILER WHICHEVER IS GREATER.
3. REFER TO DETAIL MB / BUR 7 FOR ALTERNATE WALL FLASHING METHOD.
4. FASTEN BASE FLASHING APPROXIMATELY 8" (203 mm) O.C. FOR HEIGHTS UP TO 12" (305 mm) AND 4" (102 mm) O.C. FOR HEIGHTS UP TO 24" (610 mm).
5. FOR WALL FLASHINGS IN EXCESS OF 4' (1.22 m) CONTACT GAF TECHNICAL SERVICES AT 1-800-ROOF-411 (1-800-766-3411).



GAFGLAS®
Built-Up Roofing Systems
RUBEROID®
Modified Bitumen Roofing Systems

HIGH WALL FLASHING DETAIL

DRAWING #

304

SYSTEM

STRVT

SCALE

N.T.S.

ISSUE/ REVISION DATE

8-11-14

WWW.GAF.COM
1 Campus Drive,
Parsippany, NJ 07054